

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7515-0531:106

Page 1 of 1

CATEGORY: Pipe/Fittings

LISTEE: Victaulic, PO Box 31, Easton PA 18044-0031
Contact: Mike John (610) 559-3300 Fax (610) 923-3095

DESIGN: Model PRESSFIT rubber gasketed fittings listed below. Refer to listee's data sheet for detailed product description and operational considerations.

*505	Standard Coupling
*506	Slip Coupling
*510	90° elbow
*511	45° elbow
*520	Straight Tee
*520	Reducing Tee
*550	Reducer Insert
*580	Adaptor

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, nominal size and UL label.

APPROVAL: Listed as fittings for use with plain end Schedule 5 steel pipe in dry pipe systems for temperature to -40°F. The couplings or side outlets are intended to form joints which do not need restraint.

*Corrected 09-09-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **SEPTEMBER 9, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**